

ICC-ES Evaluation Report**ESR-3135**

Issued May 1, 2013

This report is subject to renewal May 1, 2014.www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 05 00 00—METALS
Section: 05 05 23—Metal Fastenings**DIVISION: 09 00 00—FINISHES**
Section: 09 22 16.23—Fasteners**REPORT HOLDER:**
DOC'S MARKETING CORPORATION
4121 GUARDIAN STREET
SIMI VALLEY, CALIFORNIA 93063
(805) 583-9911
www.docsmarketing.com**EVALUATION SUBJECT****I-LAG™ BRAND EYE LAG SCREWS****1.0 EVALUATION SCOPE****Compliance with the following codes:**

- 2012 and 2009 *International Building Code*® (IBC)
- 2012 and 2009 *International Residential Code*® (IRC)

Property evaluated:

Structural

2.0 USES

I-Lag Brand eye lag screws are used to provide a means of attaching steel wire to the underside of unfilled steel deck for installation of suspended ceiling systems complying with IBC Section 808.1. The fasteners may be used where an engineered design is submitted in accordance with IRC Section R301.1.3.

I-Lag Brand eye lag screws are used to provide a means of attaching steel wire to the underside of unfilled steel deck for installation of suspended ceiling systems complying with IBC Section 808.1. The fasteners may be used where an engineered design is submitted in accordance with IRC Section R301.1.3.

3.0 DESCRIPTION**3.1 General:**

I-Lag Brand screws are self-drilling tapping screws. The screws have a self-drilling point and a self-tapping threaded shank below a washer-like collar. The threaded portion is nominally $\frac{1}{4}$ inch in diameter with 14 threads per inch. Above the collar, the smooth, straight shank transitions to a flattened portion with an eye for attaching the ceiling wire. See Figure 1. Recognized I-Lag Brand screws and their dimensions are listed in Table 1.

3.2 Screw Material:

The I-Lag Brand screws are manufactured from carbon steel wire complying ASTM A510, Grade 1022, that is heat-treated to obtain a Rockwell C case hardness of 50 to 56 and a Rockwell C core hardness of 30 to 40. The screws are electro-galvanized in accordance with the report holder's specifications.

3.3 Base Material:

The I-Lag Brand screws are installed into cold-formed steel deck panels, which must have a minimum specified tensile strength of 45 ksi (310 MPa). The deck panels must have a minimum rib (flute) width of $1\frac{1}{2}$ inches (38 mm) and a thickness within the range addressed in Table 3.

4.0 DESIGN AND INSTALLATION**4.1 Design:**

The available tension loads shown in Table 3 are based on the screw strength and pull-out capacity of the screws. Minimum base-metal thickness and material strength requirements for the steel supports are also given in Table 3. Capacity of the ceiling wires used with the eye lag fasteners must be considered in the connection design.

4.2 Installation:

The I-Lag Brand screws must be installed in accordance with this report and the manufacturer's published installation instructions. A copy of these instructions must be available on the jobsite at all times during installation.

The screws and ceiling wire must be installed vertically to ensure that the tension load is applied along the axis of the screw. The screws must be installed perpendicular to the supporting steel deck material, through the upper or lower flute, using a screw driving tool. When using a screw-driving pole tool recommended by the manufacturer, the installation speed must not exceed 200 rpm. The I-Lag screws may also be installed with a variable-speed drill with a maximum speed of 1,900 rpm, by using a special driver provided by the report holder.

Screws must be spaced a minimum of $\frac{3}{4}$ inch (19.1 mm) on center along the length of the deck panel, and must be installed a minimum of $\frac{3}{4}$ inch (19.1 mm) from the deck web. After installation, a minimum of three threads must protrude through the steel deck panel.

5.0 CONDITIONS OF USE

The I-Lag Brand screws described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 The fasteners are manufactured and identified in accordance with this report.
- 5.2 Fastener installation complies with this report and the manufacturer’s published installation instructions. In the event of conflict between this report and the published instructions, this report governs.
- 5.3 Available tension loads are as noted in Table 3. The stress increases and load reductions described in Section 1605.3.2 of the IBC are not allowed. No adjustments for duration of load are allowed.
- 5.4 Use of the screws to attach bracing wire to the supports is outside the scope of this report.
- 5.5 The allowable loads noted in Section 4.1 apply to the fasteners and their connection to the steel only. Adequacy of the steel deck to support the suspended loads must be justified to the satisfaction of the code official.
- 5.6 Calculations demonstrating that the applied loads are less than the allowable loads described in this report must be submitted to the code official for approval.

The calculations must be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.

- 5.7 Use of the fasteners is limited to dry, interior locations.

6.0 EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Tapping Screw Fasteners (AC118), dated June 2012.

7.0 IDENTIFICATION

The I-Lag Brand screws are embossed with four I's radiating from the shank on the top portion of the collar as shown in Figure 1. The packaging is labeled with the fastener type, part number, report holder name (Doc's Marketing) and evaluation report number (ESR-3135).

TABLE 1—I-LAG BRAND SCREWS

FASTENER TYPE	NOMINAL FASTENER SIZE (dia-tpi)	NOMINAL DIAMETER (in.)	LENGTH FROM UNDERSIDE OF COLLAR TO TIP (in.)	FASTENER “HEAD” LENGTH ¹ (in.)	EYE DIAMETER (in.)	COLLAR DIAMETER AND THICKNESS (in.)
750 SD	1/4-14	0.250	3/4	1 1/4	0.18	0.5 by 0.07
175 SD	1/4-14	0.250	1 15/16	1 1/4	0.18	0.5 by 0.07

For SI: 1 inch = 25.4 mm.

¹Length from the underside of the collar to edge of the driving end of the fastener.

TABLE—FASTENER SHEAR AND TENSION STRENGTHS (lbf)

FASTENER TYPE	NOMINAL FASTENER SIZE	NOMINAL STRENGTH		ALLOWABLE STRENGTH (ASD)		DESIGN STRENGTH (LRFD)	
		Tension, P _{ts}	Shear, P _{ss}	Tension, (P _{ts} /Ω)	Shear, (P _{ss} /Ω)	Tension, (ΦP _{ts})	Shear, (ΦP _{ss})
750SD	1/4-14	1560	2527	520	872	780	1263
175SD	1/4-14	1560	2527	520	842	780	1263

For SI: 1 inch = 25.4 mm, 1 lbf = 4.4 N.

TABLE—AVAILABLE TENSION LOADS FOR I-LAG™ BRAND SCREWS INSTALLED IN STEEL DECK PANELS (lbf)^{1,2}

FASTENER TYPE	MINIMUM DESIGN BASE METAL THICKNESS (inch)			
	0.030	0.036	0.047	0.062
ALLOWABLE STRENGTH (ASD)				
750 SD 175 SD	82	125	176	229
DESIGN STRENGTH (LRFD)				
750 SD 175 SD	131	201	281	366

For SI: 1 inch = 25.4 mm, 1 lbf = 4.4 N, 1 ksi = 6.895 MPa.

¹The tabulated allowable load values are for the screws only, based on fastener strength and pullout capacity. Ceiling wire capacity is outside the scope of this report. Deck capacity is also outside the scope of this report.


²Values are based on installation into steel having a minimum tensile strength, F_u, of 45 ksi.



COLLAR MARKING



750 SD



175 SD

FIGURE 1—I-LAG BRAND SCREWS